


Buffalo Grove Park District Lead Testing Results



BUFFALO
GROVE
PARK
DISTRICT

Alcott Center
Preschool Wing Floor Plan



Classroom	Sink Location	Results (PPB)	Course of Action
Room A	Sink 2	57.7	Shut Down
Room B	Sink 1	5.32	Hand Wash Only
Room B	Sink 2	18	Hand Wash Only
Room G	Sink 1	10.5	Hand Wash Only
Room H	Sink 1	9.51	Hand Wash Only

**Any classroom not included in this attachment was reported to have 0 - 5 ppb.*